

**QUESTIONS - ANSWERS - CLARIFICATIONS**

**CITY OF STOCKTON  
CITYWIDE SIDEWALK REPAIR  
CITY PROJECT NO.: WD22053B  
DEADLINES FOR QUESTIONS: April 13, 2023**

- 1. Would like to request the excel file for the locations list it at all possible.**

Answer: Refer to the excel sheet under the 'Plans, Attachments, and Agendas' category.

- 2. Can you please clarify if the AB under the C&G is to be 4" or 6" in depth?**

Answer: Please refer to notes #8 and #9 on City Standard Drawing No. R-55. The AB under the C&G should be 6" in depth.