



CITY OF STOCKTON

PUBLIC WORKS DEPARTMENT

MUNICIPAL SERVICE CENTER • 1465 S. Lincoln Street • Stockton, CA 95206-1941 • 209 / 937-8341 • Fax
209 / 937-8883

LETTER OF CLARIFICATION NO. 6

WEBER POINT EVENTS CENTER SHADE STRUCTURE REHABILITATION – PHASE 2 PROJECT NO. WP22033

TO ALL PROSPECTIVE BIDDERS

DATE: February 01, 2023

Letter of Clarification No. 6 for the above project consists of the following:

1. This acknowledgment form (see important Notice at the end of this document).
2. Requests for clarification shall be submitted by 2:00 p.m. on Thursday, February 02, 2023. If a request warrants a letter of clarification and sufficient time exists to prepare one, such letter of clarification will be posted on Bid Flash at least two days prior to bid opening.

SPECIFICATIONS:

1. Item No.8 of Letter of Clarification No.3 – **Revise** as follows:

Huntington Design Associates, Inc. will provide Patterning & Detailing Services to the Contractor within six weeks after the execution of the signed Construction Contract between City of Stockton and lowest responsible bidder **required submittals are approved.**

2. Item No.2 of Letter of Clarification No.4 – **Revise** as follows:

Attention is directed to the provisions in Section 8-1.05, "Time" of the Caltrans Standard Specifications and these Special Provisions.

Acquiring Materials: ~~After execution of the signed construction contract, Contractor must submit all the required submittals within ten (10) working days. As soon as all the required submittals are approved. First Notice to~~

Proceed for acquiring materials will be issued to the Contractor for ~~acquiring materials~~, as soon as **Huntington Design Associates, Inc. finishes Patterning & Detailing Services work within allocated time frame.** The Contractor shall diligently acquire all the required materials within **One Hundred Forty-Five (145) working days.** The Contractor must provide proof of ordering materials within fourteen (14) calendar days from the First Notice to Proceed date.

Active Construction: Contractor is only allowed to ~~de~~ **perform** construction from January 8 to March 31 or September 19 to November 17. After Contractor acquires all the required materials, City will issue a Second Notice to Proceed for ~~beginning the~~ **to begin** construction. The ~~contract for the performance of the work shall commence within ten (10) calendar days from the Second Notice to Proceed date and shall be diligently prosecuted to completion within~~ **Thirty (30) Forty-Five (45) working days.** The days to finish the punch list provided by the City are included in the Working Days.

3. Division 13–Tension Membrane Roof: Section 2.02 – **Add** subsection **F** as follows:

F. Nominal fabric surface area between cable work lines is 15,686 sq. ft. Contractor shall procure additional fabric as required to accommodate seam allowances, cable cuffs, corner reinforcements, and cutting waste.

Note: square footage provided above is not guaranteed.

4. Division 13 –Tension Membrane Roof : Section 3.01B – **Revise** as follows:


B. Biaxial Testing: The Sub-Contractor shall perform biaxial testing of representative samples of the tension membrane materials in order to determine its elastic properties and to set pattern compensation for the material employed in the Work.

1. At least two samples shall be tested, where the total number of test samples shall be determined by the Sub-Contractor based upon the variability of the test results and experience with the manufacturer's product.
2. The biaxial load test shall be conducted as follows:
 - a. A cruciform of fabric shall be tensioned with equal stress in warp and fill, with loading increments as follows (measured in lb. / linear in.): 0, 15, 30, 60, 30, 15, 30, 60, 30, 15, 40, 70, 40, 15, 40, 70, 40, 15, 40, 80, 40, 15, 0.
 - b. Each increment of loading shall be held for a duration of 20 minutes.

c. Warp and fill % elongation shall be recorded for each loading increment.

3. Submit bi-axial test reports for the record.

JODI ALMASSY, DIRECTOR
PUBLIC WORKS DEPARTMENT



GHAD REED, DEPUTY DIRECTOR
PUBLIC WORKS DEPARTMENT

JLA:CR:JW:TP:ASG:kc

NOTICE: THIS FORM MUST BE SIGNED AND RETURNED WITH YOUR PROPOSAL. FAILURE TO INCLUDE OR ACKNOWLEDGE A CLARIFICATION MAY RESULT IN THE PROPOSAL BEING REJECTED AS NOT RESPONSIVE.

CONTRACTOR: _____

CONTRACTOR SIGNATURE: _____

DATE: _____