

QUESTIONS-ANSWERS-CLARIFICATIONS

SOUTH AIRPORT WAY SEPARATED BIKEWAY PROJECT PROJECT NO. WT18008

Questions & Answers No. 1 – May 23, 2023

Q1. Is it required to clean the conduit and repull all the existing wire with new, or can we install the wire via the slip-in method?

A1. The City will require repull per Caltrans standards to make sure the existing wires will not be damaged with the slip in method.